

SECTION 00 91 13 ADDENDA

Addendum #1 (10/29/24): Plan revisions, callouts and details by Architect addressed, Bid Specification clarifications, irrigation wiring clarification and landscaping material substitutions.

END OF SECTION


SECTION 00 63 13 REQUEST FOR INFORMATION FORM

Project: Polo Community Park Bark Park and
Landscape Improvements
To: North of the River Recreation & Park District
Re: Irrigation

R.F.I. #: _____
From: KERN SPRINKLER
Date: _____
Proj. #: POLO-1-2425


Specification Section: _____ Paragraph: _____ Drawing Sheet: _____ Detail: _____
Request: _____

- 1) THE MAINLINE SIZE IS NOT CALLED OUT ON LI.01 OR LI.02
- 2) THE IRRIGATION SCHEDULE IS CALLING FOR BUCKNER – SUPERIOR VBM ANGLE VALVE BUT ON SHEET ID.00 DETAIL C, IT IS ASKING FOR NIBCO T-113
- 3) STATION #4 ON SHEET LI.01 IS ONLY IRRIGATING ONE HALF OF THE CIRCLE
- 4) SHEETS LI.01, LI.02, LI.03, AND LI.04 ARE CALLING OUT FOR TWO RWS-B-C PER TREE BUT ON SHEET ID.00 DETAIL J #3 IS ASKING FOR : 2 BUBBLERS MIN PER TREE AND 3 BUBBLERS PER 24” BOX

Signed By:  Printed Name: Gilbert Carmona Date: 10/23/2024
Response: _____

1. MAINLINE HAS BEEN UPDATED WITH SIZE CALLOUTS
2. DETAIL HAS BEEN UPDATED TO MATCH IRRIGATION SCHEDULE
3. LATERAL HAS BEEN ADDED TO CONNECT SYSTEM
4. DETAIL HAS BEEN UPDATED

Attachments: _____

Response From: RICHARD DEPALMA To: KERN TURF Date Open: _____ Date Ret'd: _____
Signed by:  Date: OCTOBER 28, 2024
Printed Name: RICHARD DEPALMA

END OF SECTION

SECTION 00 63 13 REQUEST FOR INFORMATION FORM

Project: <u>Polo Community Park Bark Park and</u>	R.F.I. #: <u>2</u>
<u>Landscape Improvements</u>	From: <u>Black / Hall Construction, Inc.</u>
To: <u>North of the River Recreation & Park District</u>	Date: <u>10/24/2024</u>
Re: _____	Proj. #: <u>POLO-1-2425</u>


Specification Section: _____ Paragraph: _____ Drawing Sheet: _____ Detail: _____
Request:

1. Can you please provide the license requirement for this project? Typically on projects that include multiple categories (trades) a General Contractors license (B) is required.
2. Is the owner provided equipment already in stock? If not, is there an ETA on when it will be in stock?
3. Are there any permits and/or fees required on this project? If so, permits are determined base off of and evaluation (budget).

Signed By: _____ Printed Name: _____ Date: _____
Response:

1. License requirements for the Project can be found in Sections 00 11 13 – Advertisement For Bids and 00 73 00 – Supplementary Conditions of the Bid Specifications.
2. All site features and amenities to be provided by NOR can be found in Sections 00 73 00 – Supplementary Conditions and 01 11 00 – Summary of Work. All Owner provided equipment and materials shall be provided to awarded contractor for installation within construction window.
3. Permit requirements can be found in Section 01 11 00 – Summary of Work. For this project, work is on an existing, developed NOR property. Permits are not required by a Land Use Authority for the scope of work.

Attachments:

Response From: Bid Administrator To: Bidders Date Open: 10.24.24 Date Ret'd: 10.29.24
Signed by:  Date: 10.29.24
Printed Name: JOSH HERRBOLDT

END OF SECTION

SECTION 00 63 13 REQUEST FOR INFORMATION FORM

Project: <u>Polo Community Park Bark Park and</u>	R.F.I. #: <u>3</u>
<u>Landscape Improvements</u>	From: <u>KERN SPRINKLER</u>
To: <u>North of the River Recreation & Park District</u>	Date: <u>10/28/2024</u>
Re: <u>CONDUIT AND GRO-POWER</u>	Proj. #: <u>POLQ-1-2425</u>


Specification Section: _____ Paragraph: _____ Drawing Sheet: _____ Detail: _____
Request:

- 1) ON SHEET ID.00 DETAIL E #4 IS ASKING FOR WIRE TO BE IN CONDUIT THROUGHOUT, BUT IN THE SPECS UNDER SECTION 32 80 00 IRRIGATION 3.03 e. (3) IT STATES ALL WIRING ISSUING FROM THE CONTROLLER SHALL BE DIRECT BURIAL
- 2) IN THE SPECS, SECTION 32 90 00 PLANTING PART III – EXECUTION 3.03 PLANTING TREES AND SHRUBS a. GENERAL (3) A., IT STATES TO USE GRO-POWER WITH 4% SULFUR. GRO-POWER IS NO LONGER BEING MANUFACTURED

Signed By: _____ Printed Name: Gilbert Carmona Date: 10/28/2024
Response:

1. The existing irrigation system at Polo Community Park is common/control wire; therefore, wire shall not bin in conduit and is direct burial. Contractor shall match existing irrigation system.
2. Contractors shall substitute Live Earth Humate Soil Conditioner and Tiger 90 CR Agricultural Sulphur or approved equal, instead of Gro-Power.

Attachments:

Response From: Bid Administrator To: Bidders Date Open: 10.28.24 Date Rec'd: 10.29.24
Signed by:  Date: 10.29.24
Printed Name: JOSH HERRBOLDT

END OF SECTION